

Owens Corning – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	energysystem Daily sftp 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 25° 2700 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Accumulator
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
October 23, 2013	Monitored data collected and posted on the NYSERDA DG Website

Table 3 Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	1000	
DG/CHP Generator Output Demand	Max	kW	0	4000	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - ALB

Notes: Table contains values from *owens_corning.csv*