

# CMF – Database Notes

**Table 1 Database Notes**

<b>Data Collection</b>	Data Logger: Data Collection Interval: Collection Method:	Obvius Daily sftp 5 min
<b>Site Information</b>	Azimuth: Tilt: Nameplate	195° 10° 96.792 kW
<b>DG/CHP Solar Panel Output</b>	Engineering Units: Measurement Type:	kWh Accumulator
<b>DG/CHP Solar Panel Output</b>	Engineering Units: Measurement Type:	kW Calculated

**Table 2 Event Timeline**

Date	Event
December 26, 2013	Monitored data collected and posted on the NYSERDA DG Website
August 11, 2015	Due to 70 panels having never been plugged in, data prior to June 12, 2015 has been blanked.

**Table 3. Range Checks**

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/in t	0	50	
DG/CHP Generator Output Demand	Max	kW	0	200	
Ambient Temperature	Avg	°F	-20	120	WUG Airport Code - LGA

Notes: Table contains values from *cmf\_solar.csv*