

# Target - Williamsville – Database Notes

**Table 1 Database Notes**

<b>Data Collection</b>	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	DataReadings Daily Email 15 min
<b>Site Information</b>	Azimuth: Tilt: Nameplate Capacity:	180° 10° 390 kW
<b>DG/CHP Solar Panel Output</b>	Engineering Units: Measurement Type:	kWh Interval
<b>DG/CHP Solar Panel Output Demand</b>	Engineering Units: Measurement Type:	kW Calculated

**Table 2 Event Timeline**

<b>Date</b>	<b>Event</b>
February 1, 2014	Monitored data collected and posted on the NYSERDA DG Website

**Table 3 Range Checks**

<b>Data Point</b>	<b>Hourly Data Method</b>	<b>Units</b>	<b>Database Lower Range</b>	<b>Database Upper Range</b>	<b>Notes</b>
DG/CHP Generator Output	Sum	kWh/int	0	200	
DG/CHP Generator Output Demand	Max	kW	0	800	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - BUF

Notes: Table contains values from *target\_williamsville.csv*