

Nice-Pak Products, Inc. – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Obvius Daily sftp 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	170° 10° from horizontal 854.75 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type: Power Measurements:	kWh Accumulator: Accumulated Real Energy Net
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Rate: Total Net Instantaneous Real Power

Table 2 Event Timeline

Date	Event
February 1, 2014	Monitored data collection begun
February 28, 2014	Data posted to the NYSERDA DG Website

Table 3. Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	99999	
DG/CHP Generator Output Demand	Max	kW	0	1000	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - HPN

Notes:

1. Table contains values from *nice_pak.csv*