

# The Mayfair – Database Notes

Table 1 Database Notes

|  |  |  |
|--|--|--|
| <b>Data Collection</b>                           | <u>Data Logger:</u><br><u>Data Collection Interval:</u><br><u>Collection Method:</u>                                   | Tecogen control system<br>15 – Minute<br>Nightly FTP upload to Frontier Energy servers               |
| <b>Site Information</b>                          | <u>Cogeneration Units:</u><br><u>Nameplate Capacity:</u><br><u>Heat Recovery Medium:</u><br><u>Heat Recovery Uses:</u> | One (1) Tecogen INV-100 e+ Unit<br>100 kW<br>Hot Water<br>Domestic Hot Water (DHW) and space heating |
| <b>DG/CHP Generator Electrical Output</b>        | <u>Engineering Units:</u><br><u>Energy Measurement (net/gross):</u><br><u>Measurement Type:</u>                        | kWh<br>Net Power: (calculated from gross and parasitic measurements)<br>Measured kWh                 |
| <b>DG/CHP Generator Electrical Output Demand</b> | <u>Engineering Units:</u><br><u>Energy Measurement (net/gross):</u><br><u>Measurement Type:</u>                        | kW<br>Net Power: (calculated from gross and parasitic measurements)<br>Measured kW                   |
| <b>DG/CHP Generator Fuel Input</b>               | <u>Engineering Units:</u><br><u>Measurement type:</u>  | CF<br>Pulse output from gas meter  |
| <b>DG/CHP Useful Heat Recovery</b>               | <u>Engineering Units:</u><br><u>Heat Measurement Type:</u>   | MBtu /hr<br>Calculated from 15-minute flow and temperature data                                      |
| <b>DG/CHP Unused Heat Recovery</b>               | <u>Engineering Units:</u><br><u>Heat Measurement Type:</u>   | MBtu /hr<br>Calculated from 15-minute flow and temperature data                                      |
| <b>Facility Purchased Energy</b>                 | <u>Engineering Units:</u><br><u>Measurement Type:</u>  | kWh<br>Measured kWh  |

## The Mayfair – Database Notes

|                                  |   |                   |
|----------------------------------|---|-------------------|
| <b>Facility Purchased Demand</b> | <u>Engineering Units:</u><br><u>Measurement Type:</u> | kW<br>Measured kW |
| <b>Other Facility Gas Use</b>    | <u>Engineering Units:</u><br><u>Measurement Type:</u> | -<br>-            |

### Note:

- Parasitic values incorrect due to incorrect CT ratios. CT ratios fixed 1/26/2021. The average parasitic load used to stipulate parasitic loads, replacing the incorrect values.
- Pressure compensation applied to gas use based on 20inWC gas pressure.

**Table 2 Event Timeline**

| <b>Date</b>       | <b>Event</b>  |
|-------------------|---|
| March 19, 2020    | Data collection begins  |
| October 22, 2020  | Added to NYSERDA website.                                       |
| January 26, 2021  | CT ratios corrected on parasitic meter                          |
| February 15, 2021 | Gas correction and parasitic load stipulation loaded to the web |

## The Mayfair – Database Notes

### *Range Checks*

**Table 3. Range Checks**

| <b>Data Point</b>                       | <b>Units</b> | <b>Hourly Data Calculation Method</b> | <b>Database Lower Range</b> | <b>Database Upper Range</b> | <b>Notes</b>                  |
|---|--------------|---------------------------------------|-----------------------------|-----------------------------|-------------------------------|
| DG/CHP Generator Output (WG)            | kWh/int      | Sum                                   | -2.50                       | 30                          | -                             |
| DG/CHP Generator Output Demand (WG_KW)  | kW           | Max                                   | -10                         | 120                         | -                             |
| DG/CHP Generator Gas Use (FG)           | cf/int       | Sum                                   | 0                           | 2000                        | -                             |
| Total Facility Purchased Energy (WI)    | kWh/int      | Sum                                   | 0                           | 200                         | -                             |
| Total Facility Purchased Demand (WI_KW) | kW           | Max                                   | 0                           | 800                         | -                             |
| Useful Heat Recovery (QU)               | MBtu/hr      | Avg                                   | 0                           | 1500                        | -                             |
| Unused Heat Recovery (QD)               | MBtu/hr      | Avg                                   | 0                           | 1500                        | -                             |
| Ambient Temperature (TAO)               | °F           | Avg                                   | -20                         | 130                         | <i>WUG Airport Code - LGA</i> |

## SITE NAME – THE MAYFAIR

### *Relational Checks*

**Table 4. Relational Checks**

| <b>Evaluated Point(s)</b> | <b>Criteria</b>                                     | <b>Result</b>                   |
|---------------------------|---|---------------------------------|
| Electricity Generated     | Fuel Consumed > 0 and Electricity Generated Invalid | Fuel Consumed = invalid         |
| Fuel Consumed             | Electricity Generated > 0 and Fuel Consumed Invalid | Electricity Generated = invalid |