

# Ovation In-Store – Database Notes

**Table 1 Database Notes**

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Obvius Daily sftp 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	200° 10° from horizontal 300 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type: Power Measurements:	kWh Accumulated
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

**Table 2 Event Timeline**

Date	Event
May 1, 2014	Monitored data collection begun
May 21, 2014	Data posted to the NYSERDA DG Website

**Table 3. Range Checks**

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	50	
DG/CHP Generator Output Demand	Max	kW	0	200	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - LGA

Notes:

1. Table contains values from *solar\_ovation.csv*