

## Urban Horizons – Database Notes

**Table 1 Database Notes**

<p><b>Data Collection</b></p>	<p><u>Data Logger:</u>  <u>Data Collection Interval:</u>  <u>Collection Method:</u></p>	<p>Obvius AcquiSuite A8812  15 –minute  Obvius Upload</p>
<p><b>Site Information</b></p>	<p><u>Cogeneration Units:</u>  <u>Nameplate Capacity:</u>  <u>Heat Recovery Medium:</u>  <u>Heat Recovery Uses:</u></p>	<p>Capstone C65  65 kW  Hot Water  Domestic Hot Water, Space Heating</p>
<p><b>DG/CHP Generator Electrical Output</b></p>	<p><u>Meter:</u>  <u>Engineering Units:</u>  <u>Energy Measurement (net/gross):</u>  <u>Measurement Type:</u></p>	<p>(2) Veris H8035-100 power transducer  kWh  Gross Power Measured, Net Power Calculated  Accumulated energy per interval  Power transducers for turbine output and hot water pump input</p>
<p><b>DG/CHP Generator Electrical Output Demand</b></p>	<p><u>Meter:</u>  <u>Engineering Units:</u>  <u>Measurement Type:</u></p>	<p>(2) Veris H8035-100 power transducer (same as above)  kW  Maximum 15-minute power measurement  Power transducers for turbine output and hot water pump input</p>
<p><b>DG/CHP Generator Fuel Input</b></p>	<p><u>Meter:</u>  <u>Engineering Units:</u>  <u>Measurement type:</u></p>	<p>Onicon F-5000 thermal mass meter  CF/CFH  Installed on May 14, 2015 – gas data before this date based on curve-fit of data vs power documented in <u><i>Urban Horizons Gas Data - Update 2015Jun29.pdf</i></u></p>

## Urban Horizons – Database Notes

<b>DG/CHP Useful Heat Recovery</b>	<u>Meter:</u> <u>Engineering Units:</u> <u>Heat Measurement Type:</u>	Onicon System 10 BTU Meter MBtu ( Calculated Value ) One thermal loop –BTU meter measurement for flow and two temperature measurements. Unused (rejected) heat not measured.
<b>DG/CHP Status/Runtime</b>	<u>Engineering Units:</u>	Hours Set to ON when system net power > 5 kW, calculated in 15-minute increments
<b>Facility Purchased Energy</b>	<u>Meter:</u> <u>Engineering Units:</u> <u>Measurement type:</u>	Shark 100 kWh Accumulated energy per interval
<b>Facility Purchased Demand</b>	<u>Meter:</u> <u>Engineering Units:</u> <u>Measurement type:</u>	Shark 100 kW Maximum 15-minute power measurement
<b>Other Facility Gas Use</b>	<u>Engineering Units:</u> <u>Measurement Type</u>	CF Not measured

**Table 2 Event Timeline**

<b>Date</b>	<b>Event</b>
2013/10/1	Logging begins. Microturbine gas data not valid improper meter span (see <i>Urban Horizons Gas Data - 2014Dec03.pdf</i> )
2014/2/9	Gas meter replaced. Microturbine gas data still not valid (see <i>Urban Horizons Gas Data - 2015Apr09.pdf</i> )
2015/5/14	Gas meter replaced. Microturbine gas data now in reasonable range. Curve fit of data used to fill in back data. Verification of new gas meter will use Con Ed bill from summer 2015 (when available – see <i>Urban Horizons Gas Data - Update 2015Jun29.pdf</i> )

## Urban Horizons – Database Notes

---

<b>Data Point</b>	<b>Hourly Data Method</b>	<b>Units</b>	<b>Sensor Lower Range</b>	<b>Sensor Upper Range</b>	<b>Database Lower Range</b>	<b>Database Upper Range</b>	<b>Notes</b>
DG/CHP Generator Output	Sum	kWh/int	n/a	n/a	-1	20	Negative values account for net power calculation
DG/CHP Generator Output Demand	Max	kW	n/a	n/a	-10	80	Negative values account for net power calculation
DG/CHP Generator Gas Use	Sum	cfh	n/a	n/a	0	1200	Modbus output
Total Facility Purchased Energy	Sum	kWh/int	n/a	n/a	0	40	
Total Facility Purchased Demand	Max	kW	n/a	n/a	0	160	
Other Facility Gas Use	-	cf/int	-	-	-	-	
Useful Heat Recovery	Avg	MBtu/h	n/a	n/a	0	600	
Status/Runtime of DG/CHP Generator	Sum	On/Off	n/a	n/a	0	1	Calculated based on power
Ambient Temperature	Avg	°F	-20	130	-20	130	WUG Airport Code - NYC

### ***Relational Checks***

Table 4. Relational Checks

Evaluated Point	Criteria	Result
FG	WG > 5 and FG <=0	DQ Level for FG set to 2

Notes:        FG – DG/CHP Generator Gas Use  
              WG–DG/CHP Generator Output

### ***Additional Adjustments to Data***

- None