

Cinemark Site #202 Rochester NY – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Obvius AcquiSuite Daily Upload 15 min
Site Information	Solar Panels: Azimuth: Tilt: Nameplate Capacity:	1 178° 20° 312.13 kW DC
DG/CHP Solar Panel Output	Engineering Units: Measurement Type: Power Measurements:	kWh Interval
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Interval

Table 2 Event Timeline

Date	Event
August 13, 2014	Monitored data collected and posted on the NYSERDA DG Website

Cinemark Site #202 Rochester NY – Database Notes

Range Checks

Table 3. Range Checks

Data Point	Hourly Data Method	Units	Sensor Lower Range	Sensor Upper Range	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	-	0	100	<i>Interval Size: 15 mins</i>
DG/CHP Generator Output Demand	Max	kW	0	-	0	400	
Ambient Temperature	Avg	°F	-20	130	-20	130	WUG Airport Code - ROC

Notes:

1. Table contains values from *cinemark.csv*