

## Toledo Building – Database Notes

Table 1 Database Notes

<b>Data Collection</b>	<u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u>	Obvius Aquisuite A8812 1 – Minute Obvius Upload Manager to CDH servers
<b>Site Information</b>	<u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u> <u>Excess Heat:</u>	Aegen TP-75LE Synchronous w/ Inverter 75 kW Hot Water Domestic hot water, space heating, pool heating Rejected to atmosphere by dump radiator
<b>DG/CHP Generator Electrical Output</b>	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u>	kWh Net Power (calculated from gross and parasitic measurements) Accumulated kWh
<b>DG/CHP Generator Electrical Output Demand</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Calculated : accumulated kWh/int * # intervals
<b>DG/CHP Generator Fuel Input</b>	<u>Engineering Units:</u> <u>Measurement type:</u>	CF Pulse output from utility meter (not yet installed)
<b>DG/CHP Useful Heat Recovery</b>	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu/hr Calculated from 1 minute analog flow and temperature data
<b>DG/CHP Unused Heat Recovery</b>	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu/hr Calculated from 1 minute analog flow and temperature data
<b>DG/CHP Status/Runtime</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	Hours Calculated based on generator output

## Toledo Building – Database Notes

<b>Facility Purchased Energy</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	kWh Accumulated kWh
<b>Facility Purchased Demand</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Calculated : accumulated kWh/int * # intervals
<b>Other Facility Gas Use</b>	<u>Engineering Units:</u> <u>Measurement Type:</u>	- -

**Table 2 Event Timeline**

<b>Date</b>	<b>Event</b>
September 9, 2014	CDH on site to install data logger and terminate sensor wiring, data collection begins.
December 4, 2014	Cogen unit operation begins.
March 30, 2015	CDH on site to verify metering.
November 22, 2019	Useful loop temperature no longer reporting. Heat recovery and related thermal efficiency not calculated.
January 29, 2020	Useful loop temperature reporting.
June 16, 2020	Supply loop temperature no longer reporting. Heat recovery and related thermal efficiency not calculated.
August 14, 2020	Supply loop temperature reporting.
July 5, 2021	Data reporting to DER website ends. Thermal efficiency consistently exceeds 65%.

# Toledo Building – Database Notes

## Toledo Building – Database Notes

### *Range Checks*

**Table 3. Range Checks**

<b>Data Point</b>	<b>Units</b>	<b>Hourly Data Calculation Method</b>	<b>Database Lower Range</b>	<b>Database Upper Range</b>	<b>Notes</b>
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	2	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	100	$WG\_KW\_d = WG\_d * \# \text{ Intervals}$
DG/CHP Generator Gas Use (FG_d)	cf/int	-	-	-	<i>Meter not yet installed</i>
Total Facility Purchased Energy (WT_d)	kWh/int	Sum	0	10	
Total Facility Purchased Demand (WT_KW_d)	kW	Max	0	600	$WT\_KW\_d = WT\_d * \# \text{ Intervals}$
Other Facility Gas Use (FT_d)	cf/int	-	-	-	
Useful Heat Recovery (QHR_d)	MBtu/hr	Avg	0	800	
Unused Heat Recovery (QD_d)	MBtu/hr	Avg	0	800	
Status/Runtime of DG/CHP Generator (SG_d)	hr	-	-	-	
Ambient Temperature (TAO)	°F	Avg	-20	130	<i>WUG Airport Code - NYC</i>

Notes:

1. This table contains values from *birchwood\_toledo.csv*

# Toledo Building – Database Notes

## *Relational Checks*

**Table 4. Relational Checks**

<b>Evaluated Point</b>	<b>Criteria</b>	<b>Result</b>

Notes:

1. This table contains values from *relational\_checks.pro*