Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method:	Obvius Aquisuite A8812 1 – Minute Obvius Upload Manager to CDH servers
Site Information	Cogeneration Units: Nameplate Capacity: Heat Recovery Medium: Heat Recovery Uses: Excess Heat:	Four (4x) Aegen TP-75LE Induction w/ Inverter 75 kW each – 300 kW combined Hot Water Domestic hot water and space heating Rejected to atmosphere by dump radiator
DG/CHP Generator Electrical Output	Engineering Units: Energy Measurement (net/gross): Measurement Type:	kWh Net Power (calculated from 4x gross and 1x parasitic measurements) Accumulated kWh
DG/CHP Generator Electrical Output Demand	Engineering Units: Measurement Type:	kW Calculated: accumulated kWh/int * # intervals
DG/CHP Generator Fuel Input	Engineering Units: Measurement type:	CF Accumulated cubic feet
DG/CHP Useful Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu/hr Calculated from 1 minute analog flow and temperature data
DG/CHP Unused Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu/hr Calculated from 1 minute analog flow and temperature data
DG/CHP Status/Runtime	Engineering Units: Measurement Type:	Hours Calculated based on generator output

Facility Purchased Energy	Engineering Units: Measurement Type:	kWh Accumulated kWh
Facility Purchased Demand	Engineering Units: Measurement Type:	kW Calculated: accumulated kWh/int * # intervals
Other Facility Gas Use	Engineering Units: Measurement Type:	-

Table 2 Event Timeline

Date	Event
April 2, 2015	CDH on site to install data logger and terminate sensor wiring.
May 1, 2015	CDH on site to setup communications and wire additional metering. Data collection begins.

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	6	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	360	$WG_KW_d = WG_d * # Intervals$
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	70	
Total Facility Purchased Energy (WT_d)	kWh/int	Sum	0	10	
Total Facility Purchased Demand (WT_KW_d)	kW	Max	0	600	$WT_KW_d = WT_d * \# Intervals$
Other Facility Gas Use (FT_d)	cf/int	-	-	-	
Useful Heat Recovery (QHR_d)	MBtu/hr	Avg	0	2,500	
Unused Heat Recovery (QD_d)	MBtu/hr	Avg	0	2,500	
Status/Runtime of DG/CHP Generator (SG_d)	hr	-	-	-	
Ambient Temperature (TAO)	°F	Avg	-20	130	WUG Airport Code - NYC

Notes:

1. This table contains values from bay_club_1.csv

Relational Checks

Table 4. Relational Checks

Evaluated Point	Criteria	Result

Notes:

1. This table contains values from relational_checks.pro