

## Oneida County Corrections Facility – Database Notes

**Table 1 Database Notes**

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Obvius Aquisuite (CDH) 1-minute Nightly Obvius Building Manager Online upload to CDH Servers Eastern Standard Time
Site Information	Cogeneration Units: Nameplate Capacity: Heat Recovery Medium: Heat Recovery Uses: Excess Heat Use:	One (1) Aegen TP75-LE Cogen Unit 75 kW Hot water Domestic Hot Water, Boiler Rejected to atmosphere using dump radiator
DG/CHP Generator Electrical Output	Engineering Units: Energy Measurement (net/gross): Measurement Type:	kWh Net calculated: Gross minus parasitic Calculated using kW measurements from 1x cogen power meters (Veris H8035) and 1x parasitic power calculated from current going to CCP
DG/CHP Generator Electrical Output Demand	Engineering Units: Measurement Type:	kW Average power measurement, based on peak 1-minute power
DG/CHP Generator Fuel Input	Engineering Units: Measurement Type:	CF Pulse
DG/CHP Useful Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu (calculated value) Calculated using 1-minute flow and temperature measurements
DG/CHP Unused Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu Calculated using 1-minute flow and temperature measurements
DG/CHP Status/Runtime	Engineering Units:	0 – 1, System ON/System Off

## Oneida County Corrections Facility – Database Notes

---

Facility Purchased Energy	Engineering Units:	Not collected
Facility Purchased Demand	Engineering Units:	Not collected
Other Facility Gas Use	Engineering Units:	Not collected

**Note: See addendum for further details**

**Table 2 Event Timeline**

Date	Event
February 23, 2016	Logging begins.
February 23, 2016	CDH on site to verify flow and temperature sensor measurements. Collect instantaneous DG/CHP measurements for meter verification. Installed strap on temperature sensor and terminate gas meter wiring.

## Oneida County Corrections Facility – Database Notes

---

### **Range Checks**

Table 3. Range Checks

<b>Data Point</b>	<b>Hourly Data Method</b>	<b>Units</b>	<b>Database Lower Range</b>	<b>Database Upper Range</b>	<b>Notes</b>
DG/CHP Generator Output	Sum	kWh/int	-1	2	Database range account for parasitic loads
DG/CHP Generator Output Demand	Max	kW	-10	100	
DG/CHP Generator Gas Use	Sum	cf/int	0	20	
Total Facility Purchased Energy	Sum	kWh/int	-	-	Not installed
Total Facility Purchased Demand	Max	kW	-	-	Not installed
Other Facility Gas Use	Sum	cf/int	-	-	Not installed
Useful Heat Recovery	Sum	MBtu/int	0	800	Calculated Value
Unused Heat Recovery	Sum	MBtu/int	0	800	Calculated Value
Status/Runtime of DG/CHP Generator	On/Off	On/Off	0	1	0 – 1, System On/System Off
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - RME

Notes:

1. This table contains values from *oneida\_cc.csv*

***Relational Checks***

Table 4. Relational Checks

Evaluated Point	Criteria	Result