<u>Parc East – Database Notes</u>

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method:	Obvius Acquisuite Data Logger 1 – Minute Nightly Obvius Building Manager Online upload to CDH servers
Site Information	Cogeneration Units: Nameplate Capacity: Heat Recovery Medium: Heat Recovery Uses: Excess Heat:	Aegen TP-75LE Induction w/ Inverter 75 kW Hot Water Domestic hot water/Space Heating Rejected to atmosphere by dump radiator
DG/CHP Generator Electrical Output	Engineering Units: Energy Measurement (net/gross): Measurement Type:	kWh Net Power (calculated from gross and parasitic measurements) Accumulated kWh
DG/CHP Generator Electrical Output Demand	Engineering Units: Measurement Type:	kW Net Power (calculated from gross and parasitic measurements) Calculated : accumulated kWh/int * # intervals
DG/CHP Generator Fuel Input	Engineering Units: Measurement type:	CF Accumulated cubic feet
DG/CHP Useful Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu/hr Calculated from 1 minute analog flow and temperature data
DG/CHP Unused Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu/hr Calculated from 1 minute analog flow and temperature data
DG/CHP Status/Runtime	Engineering Units: Measurement Type:	Hours Calculated based on generator output

Parc East – Database Notes

Facility Purchased Energy	Engineering Units: Measurement Type:	kWh Accumulated kWh
Facility Purchased Demand	Engineering Units: Measurement Type:	kW Calculated: accumulated kWh/int * # intervals
Other Facility Gas Use	Engineering Units: Measurement Type:	-

Table 2 Event Timeline

Date	Event
June 20, 2016	Data was sent to CDH Energy June 20, 2016
November 7, 2016	Website data begins November 4, 2016

Parc East - Database Notes

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	80	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	120	
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	1000	
Total Facility Purchased Energy (WT_d)	kWh/int	Sum	0	600	
Total Facility Purchased Demand (WT_KW_d)	kW	Max	0	600	
Other Facility Gas Use (FT_d)	cf/int	-	-	-	
Useful Heat Recovery (QHR_d)	MBtu/hr	Avg	0	2000	
Unused Heat Recovery (QD_d)	MBtu/hr	Avg	0	2000	
Status/Runtime of DG/CHP Generator (SG_d)	hr	Status	0	1	
Ambient Temperature (TAO)	°F	Avg	-30	120	WUG Airport Code - NYC

Notes:

1. This table contains values from *parc_east.csv*

<u>Site Name – Database Notes</u>

Relational Checks

Table 4. Relational Checks

Evaluated Point	Criteria	Result

Notes:

1. This table contains values from relational_checks.pro