## **Marcus Garvey – Database Notes**

**Table 1 Database Notes** 

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Locus Daily Locus Energy Email 15 min		
Site Information	Azimuth: Tilt: Nameplate Capacity:	169° 5.97° 479.71 kW		
DG/CHP Solar Panel	Engineering Units:	kWh		
Output	Measurement Type:	Interval		
DG/CHP Solar Panel	Engineering Units:	kW		
Output Demand	Measurement Type:	calculated		

## **Table 2 Event Timeline**

Date	Event	
December 19, 2016	Monitored data collection began	
December 19, 2016	Monitored data transfer to CDH Energy began	
January 4, 2017	nitored data posted on the NYSERDA DG Website	

Table 3. Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	125	
DG/CHP Generator Output Demand	Max	kW	0	500	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code – LGA

Notes: Table contains values from marcus\_garvey.csv

CDH Energy Corp. January 2017