

Plaza Residence 250

A scaling factor change on the parasitic power meter resulted in an increased parasitic load of 20 kW for the CHP system. In an effort to post realistic net generation, a stipulated parasitic load was calculated using past measurements when the meter was reading accurately.

