

# DP 35 LLC – Database Notes

**Table 1 Database Notes**

<b>Data Collection</b>	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	energysystem Daily sftp 15 min
<b>Site Information</b>	Azimuth: Tilt: Nameplate Capacity:	170° 5° 50 kW
<b>DG/CHP Solar Panel Output</b>	Engineering Units: Measurement Type:	kWh Accumulator
<b>DG/CHP Solar Panel Output Demand</b>	Engineering Units: Measurement Type:	kW Calculated

**Table 2 Event Timeline**

Date	Event
September 1, 2014	Monitored data collection begun
January 27, 2015	Data posted to the NYSERDA DG Website

**Table 3 Range Checks**

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	99999	
DG/CHP Generator Output Demand	Max	kW	0	60	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - HPN

Notes: Table contains values from *dp35llc\_solar.csv*