

Hamilton Fulton Montgomery BOCES – Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Obvius AcquiSuite Daily HTTP Upload 5 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 25° 724.68 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Accumulator
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Average

Table 2 Event Timeline

Date	Event
September 25, 2017	Monitored data collection began
October 5, 2017	Monitored data posted on the NYSERDA DG Website

Table 3. Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	62.5	
DG/CHP Generator Output Demand	Max	kW	0	750	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code - ALB

Notes: Table contains values from *hfm_boces.csv*