

## Green Hills Home – Database Notes

**Table 1 Database Notes**

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Aegis Data Collection Platform 15-minute Nightly FTP upload to CDH Energy servers Eastern Standard Time
Site Information	Cogeneration Units: Nameplate Capacity: Heat Recovery Medium: Heat Recovery Uses: Excess Heat Use:	One (1) Yanmar CP35D1Z 35 kW Hot water Domestic Hot Water, Space Heating Exhaust bypasses heat recovery HX, vented to atmosphere
DG/CHP Generator Electrical Output	Engineering Units: Energy Measurement (net/gross): Measurement Type:	Not Collected - Not Required for Systems < 50 kW
DG/CHP Generator Electrical Output Demand	Engineering Units: Measurement Type:	Not Collected - Not Required for Systems < 50 kW
DG/CHP Generator Fuel Input	Engineering Units: Measurement Type:	Not Collected - Not Required for Systems < 50 kW
DG/CHP Useful Heat Recovery	Engineering Units: Heat Measurement Type:	MBtu /hr Accumulated MBtu from integrating BTU meter
DG/CHP Unused Heat Recovery	Engineering Units: Heat Measurement Type:	Not Collected
DG/CHP Status/Runtime	Engineering Units:	Not Collected
Facility Purchased Energy	Engineering Units: Measurement Type:	Not Collected
Facility Purchased Demand	Engineering Units: Measurement Type:	Not Collected
Other Facility Gas Use	Engineering Units:	Not collected

## Green Hills Home – Database Notes

---

**Table 2 Event Timeline**

<b>Date</b>	<b>Event</b>
January 22, 2018	Data collection begins.

## Green Hills Home – Database Notes

---

### **Range Checks**

**Table 3. Range Checks**

<b>Data Point</b>	<b>Hourly Data Method</b>	<b>Units</b>	<b>Database Lower Range</b>	<b>Database Upper Range</b>	<b>Notes</b>
DG/CHP Generator Output (WG_d)	Sum	kWh/int	-	-	No Data
DG/CHP Generator Output Demand (WG_KW_d)	Max	kW	-	-	No Data
DG/CHP Generator Gas Use (FG_d)	Sum	Cfh	-	-	No Data
Total Facility Purchased Energy (WT_d)	Sum	kWh/int	-	-	No Data
Total Facility Purchased Demand (WT_KW_d)	Max	kW	-	-	No Data
Other Facility Gas Use (FT_d)	Sum	Cfh	-	-	No Data
Useful Heat Recovery (QHR_d)	Avg	MBtu/h	0	1000	
Unused Heat Recovery (QD_d)	Avg	MBtu/h	-	-	No Data
Status/Runtime of DG/CHP Generator (SG_d)	On/Off	On/Off	-	-	No Data
Ambient Temperature (TAO)	Avg	°F	-30	120	WUG Airport Code - HPN

**Notes:**

1. This table contains values from green\_hills\_home.csv

***Relational Checks***

Table 4. Relational Checks

Evaluated Point	Criteria	Result